

MONROE COUNTY ROAD COMMISSION
NOTICE TO BIDDERS INQUIRY RESPONSE

Disclaimer: This Notice to Bidders is being provided by the Monroe County Road Commission (MCRC) as a courtesy service to contractors. In preparation of this Notice to Bidders, the Monroe County Road Commission has endeavored to offer current, correct and clearly expressed information. This information is not a part of the contract documents and has no contractual standing. The information provided will not be accepted as documentation as a basis to file a claim.

MCRC Project No.: 489-002-179031
Project Description: Sandywell Drive Special Assessment District
Bid Date: Tuesday, June 27, 2017 at 10:00 a.m.
Responded By: Michael Smith
Response Date: 06/22/2017

The following question(s) and answer(s) are provided below in response to an inquiry received regarding the above project:

Question No. 1: How will the aggregate base under the curbs be paid for since you are putting down 10" for a portion and 8" for a portion on the roadway. It does not show the thickness under the curbs, but it usually is 6" thick. You have a pay item for 6" aggregate base, but the quantity lines up with driveway quantities.

Answer No. 1: The aggregate base under the concrete curb and gutter shall be installed as shown on the typical cross sections on Sheet 4 of the plans, and the aggregate will be paid for as either **Aggregate Base, 8 inch** or **Aggregate Base, 10 inch** depending on the location of the curb and gutter. The Engineer will measure **Aggregate Base, __ inch** by the width and length as shown on the plans, and no deductions will be made for the reduced thickness of the aggregate base under the concrete curb and gutter.