

MONROE COUNTY ROAD COMMISSION
NOTICE TO BIDDERS INQUIRY RESPONSE

Disclaimer: This Notice to Bidders is being provided by the Monroe County Road Commission (MCRC) as a courtesy service to contractors. In preparation of this Notice to Bidders, the Monroe County Road Commission has endeavored to offer current, correct and clearly expressed information. This information is not a part of the contract documents and has no contractual standing. The information provided will not be accepted as documentation as a basis to file a claim.

MCRC Project No.: 494-002-189042
Project Description: Mohawk Trails Special Assessment District
Bid Date: Thursday, January 25, 2018 at 10:00 a.m.
Responded By: Michael Smith
Response Date: 01/22/2018

The following question(s) and answer(s) are provided below in response to an inquiry received regarding the above project:

Question No. 1: When reviewing the plans and quantities for the driveway removals and replacements, it appears that something is being done to all the driveways on this project, but it is not shown on the plans as being removed and replaced except where the new culverts are being installed. Please clarify.

Answer No. 1: A portion of each driveway within the project limits will be removed and replaced as part of the project. The driveway replacement detail on sheet 4 of the plans shows a typical driveway removal and replacement length ranging from 4 feet to 9 feet. The estimated quantities for each driveway are listed in the driveway tables on sheet 12 of the plans.

Question No. 2: The Class F culvert at Station 402+47 on Pawnee Trail on sheet 11 of the plans indicates the a 10 inch diameter for the culvert, but there is not a pay item for Culv, CI F, 10 inch in the schedule of items in the proposal. Please clarify.

Answer No. 2: The references to the Culv, CI F, 10 inch item of work on sheet 11 are incorrect. The correct diameter for the proposed driveway culvert at Station 402+47 on Pawnee Trail is 12 inch, and the pay item for the proposed culvert is Culv, CI F, 12 inch.