

MONROE COUNTY ROAD COMMISSION
NOTICE TO BIDDERS INQUIRY RESPONSE

Disclaimer: This Notice to Bidders is being provided by the Monroe County Road Commission (MCRC) as a courtesy service to contractors. In preparation of this Notice to Bidders, the Monroe County Road Commission has endeavored to offer current, correct and clearly expressed information. This information is not a part of the contract documents and has no contractual standing. The information provided will not be accepted as documentation as a basis to file a claim.

MCRC Project No.: 494-02-160653 and 505-002-160654
Project Description: Chapel Creek and Wild Haven Park Special Assessment Districts
Bid Date: Tuesday, July 12, 2016 at 10:00 a.m.
Responded By: Michael Smith
Response Date: 07-05-2016

The following question(s) and answer(s) are provided below in response to an inquiry received regarding the above project:

Question No. 1: Is the tree that is to be removed in Wild Haven Park the one in the island where the road splits?

Answer No. 1: The tree to be removed is located at the south end of the subdivision as noted on page 23 of the proposal.

Question No. 2: What are we to do with that area after the tree is removed?

Answer No. 2: Grind the tree stump to a minimum depth of 8 inches below the surrounding ground surface. Backfill the hole flush with the surrounding surface with wood chips from the stump grinding operation.

Question No. 3: In Wild Haven Park, are we supposed to pave back on the driveways? If so, do we need to mill butt joints?

Answer No. 3: The driveways in Wild Haven Park shall be paved back three (3) feet from the edge of the pavement per the detail on page 22 of the proposal. The HMA mixture shall be feathered onto the existing driveway surface. A milled butt joint will not be required.